



## Classification report on fire resistance

in accordance with EN 13501-2 : 2016

– *Translation* –

**Classification report no.:**

K-2102/245/19-MPA BS

**Client:**

DOLLE AS  
Vestergade 47  
7741 Froestrup, Dänemark

**Product to be classified:**

Separating floor  
“Loadbearing, separating, heat-insulating timber joist floor combined with two attic stairs (one with a steel ladder, the other with a timber ladder)”

**Number of notified testing body:** 0761-CPR

**Issue no.:** 1<sup>st</sup> version

**Issue date:** 03/02/2020

This classification report comprises 4 pages.

This document may only be circulated as a complete text without alterations. Excerpts or abridged versions of this document are subject to approval in writing of MPA Braunschweig. Translations of this document that are made without the approval of MPA Braunschweig must bear the note “translation of the German original not examined by MPA Braunschweig”. The first sheet of this document and the page carrying the signatures bear the official stamp of MPA Braunschweig. Documents without signature and the official stamp are invalid. The test material has been fully used.

## 1 Introduction

This classification report on fire resistance defines the classification assigned to the component “Loadbearing, separating, heat-insulating timber joist floor combined with two attic stairs (one with a steel ladder, the other with a timber ladder)” in accordance with the procedures stipulated in EN 13501-2 : 2016.

## 2 Details of the classified product

### 2.1 Function information

The “Loadbearing, separating, heat-insulating timber joist floor combined with two attic stairs (one with a steel ladder, the other with a timber ladder)” is defined as loadbearing floor combined with two installations.

### 2.2 Description

The component “Loadbearing, separating, heat-insulating timber joist floor combined with two attic stairs (one with a steel ladder, the other with a timber ladder)” is fully described in the test reports listed in Section 3.1

## 3 Test reports and test results used to substantiate this classification

### 3.1 Test results

Name of testing laboratory	Name of client	Number of test report	Testing method
MPA Braunschweig	DOLLE AS Vestergade 47 7741 Froestrup, Dänemark	2101/463/18–Wein dated 10/10/2019	DIN EN 1365-2 : 2000-02, DIN EN 1363-1 : 2012-10

### 3.2 Results

Component	Separating floor under exposure to fire from below		
Testing method, quantity and date	Parameter(s)	Results	
DIN EN 1365-2 : 2000-02, Test Report No. 2101/463/18–Wein dated 10/10/2019	Fire load:	Standard temperature-time curve in accordance with DIN EN 1363-1 : 2012-10	
	Direction of fire load:	From below	
	Load applied:	1.74 kN/m <sup>2</sup>	
	Loadbearing capacity:	> 47 min	
	Integrity	Cotton pad	> 47 min
		Gap gauge	> 47 min
		Sustained flaming	> 47 min
	Thermal insulation	I	46 min
	Radiation	W	-
Mechanical load	M	-	

## 4 Classification and scope of application

### 4.1 Basis for the classification

This classification was performed in accordance with EN 13501-2 : 2016, Section 7.

The test reports in accordance with EN 1365-2 : 2000-02 in conjunction with EN 1363-1 : 2012-10, as listed in Section 3.1, were checked by MPA Braunschweig. The results are assessed in this classification report in accordance with the currently applicable test standards EN 1365-2 : 2015-02 and EN 1363-1 : 2012-10 and considered suitable for classification in accordance with DIN EN 13501-2 : 2016.

### 4.2 Classification

The component “Loadbearing, separating, heat-insulating timber joist floor combined with two attic stairs (one with a steel ladder, the other with a timber ladder)” is classified by the following combinations of performance parameters and classes:

<b>R</b>	<b>E</b>	<b>I</b>	<b>W</b>		<b>tt</b>	<b>-</b>	<b>M</b>	<b>S</b>	<b>C</b>	<b>IncSlow</b>	<b>sn</b>	<b>ef</b>	<b>r</b>
<b>x</b>	<b>x</b>	<b>x</b>	<b>-</b>		<b>x</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>

#### 4.2.1 Separating floor under exposure to fire on the underside

**Fire resistance classification: REI 45**

#### 4.3 Scope of application

The component has the following field of direct application in accordance with EN 13501-2 : 2016 in conjunction with EN 1365-2 :2015-02.

The test results are directly applicable to constructions that deviate from the tested one in one or several of the following aspects:

- a) The maximum moments and shear forces must not exceed the tested values, while applying a calculation basis that corresponds to the one that led to the determination of the test load;
- b) The board dimensions of the underside cladding may exceed the tested dimensions by maximally 5 % or 50 mm;
- c) The dimensions of the largest opening tested or the largest attic stairs tested must not be exceeded;
- d) The height of cavity H and the distance d between the underside cladding and the load-bearing timber beam must correspond at the to the tested dimensions ( $H \geq 200$  mm,  $d \geq 30$  mm);
- e) No additional combustible materials or additional insulating materials other than the tested ones may be installed. An increase in the combustible mass (materials) is not admissible.

### 5 Restrictions

The classification document cannot be construed as type approval or certification for the product.

<b>Classification report</b>	<b>Name</b>	<b>Signature <sup>a)</sup></b>	<b>Date</b>
<b>Prepared by</b>	M. Weingarten		03/02/2020
<b>Checked by</b>	G. Blume		03/02/2020

<sup>a)</sup> For and on behalf of: Materialprüfanstalt für das Bauwesen, Braunschweig

*This document is the translated version of Classification Report no. K-2102/245/19-MPA BS dated 21/01/2020. The legally binding text is the aforementioned German classification report.*